

**Project: Recovery of water supply and wastewater system facilities on the territory of Velyka Dymerka Village Territorial Community of Brovary district, Kyiv region**

**Tender: VDM\_WW\_1 "Design, supply, construction and installation works for reconstruction of wastewater treatment plant of Shevchenkove Village of Brovary district, Kyiv region"**

**Amendment No 2 dated 26.02.2024 to Tender Documentation dated 24.01.2024**

Due to the identified inconsistencies of the Tender documentation VDM\_WW\_1, this Amendment No. 2 to the Tender documentation, the Employer makes changes to:

**1. Section III Tender Forms, namely to the Price Schedules**

Description of item 1.4.4, **Price Schedule 1.4 Process Equipment of Treatment Plants** shall be changed and read as follows:

<b>Original</b>	<b>Amended</b>
<i>Sanitary pump, capacity - 80 m<sup>3</sup>/h</i>	<i>Sanitary pump, capacity - 32 m<sup>3</sup>/h</i>

Updated version of VDM\_WW\_1\_III\_Price Schedules is attached (Annex 1 to Amendment No. 2).

**2. Section IV Employer's Requirements**

The information provided in item 3.3.2.9 **Sludge dewatering component** shall be changed and read as follows:

<b>Original</b>	<b>Amended</b>
<i>..... Excess biological sludge and other sediments are sent to a container for flow normalization before the dewatering unit (screw type).....</i>	<i>..... Excess biological sludge and sediments from clarifiers are sent to a container for flow normalization before the dewatering unit (screw type).....</i>

**3. Principal technological scheme VDM\_WW\_1\_Annex IV.4.1.**

Principal technological scheme has been changed according to updated Section IV Employer's Requirements.

Updated version of VDM\_WW\_1\_Annex IV.4.1\_Principal technological scheme is attached (Annex 2 to Amendment No. 2).

Other provisions of the Tender Documentation are not amended.